



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2025/ 653

Dated: 14/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **Stanford Convent School** located at **D-55, Kasana Complex, Jaitpur Road, Badarpur Boarder, New Delhi-44**, comprised of **Basement + Ground + 03 upper floors**, was granted Fire Safety Certificate (FSC) by this department vide letter no. F6/DFS/MS/School/2022/SZ/130 dated 08.02.2022. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 09.05.2025 in the presence of Mr. Aman Kasana (Owner) and found that the school has complied with the fire prevention and fire safety requirements in accordance with the circular no. F6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Directorate of Education and the building is fit for occupancy of Group B **"Educational Building"** with effect from 14/05/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 14/05/2025 at New Delhi by

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, Stanford Convent School located at D-55, Kasana Complex, Jaitpur Road, Badarpur Boarder, New Delhi-44.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.